

**ADDENDUM NO. 2
CANYONLANDS FIELD
February 26, 2018**

TO: All Planholders

RE: Storm Drainage Plan

The following Addendum shall be incorporated into the Contract Documents for the above-referenced project and shall supersede all contrary and conflicting information, which are hereby supplemented or revised in certain particulars in the following:

I. CONTRACT DOCUMENTS

A. **N.A.**

II. CONSTRUCTION PLANS

A. **N.A.**

IV. CLARIFICATION

- A. Concrete: Concrete for drainage pan can be standard UDOT mix design capable of 4000 PSI strength acceptance. Bidder will provide testing of concrete mix.
- B. Bid Bond: The bid bond for the project will be standard 5%.
- C. Soil Compaction Testing: The bidder will perform compaction testing of subgrade.
- D. Site survey: Grand County will supply survey of site location.

Additional Questions, please contact:

Judd Hill

Canyonlands Field Airport

435-259-4849

jhill@grandcountyutah.net

END OF ADDENDUM NO. 2